

### Bid Document

Bid Details	
Bid End Date/Time	03-08-2020 10:00:00
Bid Opening Date/Time	03-08-2020 10:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Science And Technology
Department Name	Department Of Science And Technology (dst)
Organisation Name	Indian Institute Of Astrophysics (iia)
Office Name	Bengaluru
Total Quantity	90
Item Category	modular electrical switches and accessories , non modular electrical switches and accessories flush type
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Primary product category	modular electrical switches and accessories
Inspection Required	No

#### EMD Detail

Required	No
----------	----

#### ePBG Detail

Required	No
----------	----

#### Splitting

Bid splitting not applied.

### Modular Electrical Switches And Accessories ( 10 pieces )

#### Technical Specifications

[\\* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Electrical Accessory for	6A & amp; 16 A, 6 Pin	6A & amp; 16 A, 6 Pin

	<b>domestic &amp; similar purpose</b>	Socket, as per IS:1293/2005 with latest amendments	Socket, as per IS:1293/2005 with latest amendments
	<b>Size Designation</b>	2 M	2 M
	<b>Product ISI Marked</b>	No	No
	Valid BIS License Number	-	*
	Color as seen from front side (Matching with cover plate)	White	*
CONSTRUCTIONAL	Shutter with socket	With	*
	Current carrying part must be of Brass, Copper, or any other superior material	Yes	*
	Type of Accessories	Modular	*
	Body material	Polycarbonate Electrical Grade	*
	Mechanical Strength of Blank Plate, Coaxial Antina Socket and Telephone Jack as per IS:3854	NA	*
	Marking of manufacturer name /Trade mark on accessories	Yes	*
FUNCTIONAL	Rated Voltage (Volt)	230 Volt	*
	Resistance to Abnormal Heat and Fire of Blank Plate, Coaxial Antina Socket and Telephone Jack as per IS:3854	NA	*
	Snapfit accessories shall withstand atleast 5 operations of fixing and removing ,causing no damage to the component nor they shall fall loose.	Yes	*
CERTIFICATIONS	Availability of complete and satisfactory type test Report from Central govt/ NABL/ ILAC accredited laboratory to prove conformity to the specification	Yes	*
	Name of lab where test conducted	-	*
	Test certificate number	-	*
	Test report date	-	*
	Test report to be submitted to the Buyer on Demand	Yes	*
	OEM Product Series	-	*

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

#### **Additional Specification Documents**

#### **Consignees/Reporting Officer and Quantity**

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Anbazhagan P	635701,Kavalur Alangayam contact Mr. Rajinikanth :9884534310	10	15

### Non Modular Elecrical Switches And Accessories Flush Type ( 50 meter )

#### Technical Specifications

[\\* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	<b>Electrical Accessory for domestic &amp;&amp; similar purpose</b>	6A, 5 Pin Switch socket combination, switch to IS:3854/1997 and socket as per IS:1293/2005 with latest amendments	6A, 5 Pin Switch socket combination, switch to IS:3854/1997 and socket as per IS:1293/2005 with latest amendments
	<b>Product ISI Marked</b>	Yes	Yes
	Valid BIS License Number	-	*
CONSTRUCTIONAL	Shutter with socket	With	*
	Current carrying part must be of Brass, Copper, or any other superior material	Yes	*
	Type of Accessories	Flush Type	*
	Body material	Polycarbonate Electrical Grade	*
	Color as seen from front (Matching with other accessories)	White	*
	Accessories shall be provided with fixing screw with each set of packing	Yes	*
	Mechanical Strength of Coaxial Antina Socket, Telephone Jack and Indicator as per IS:3854	Yes	*
FUNCTIONAL	Rated Voltage (Volt)	250 vOLT	*
	Resistance to Abnormal Heat and Fire of Coaxial Antina Socket, Telephone Jack and Indicator as per IS:3854	Yes	*
CERTIFICATIONS	Availability of complete and satisfactory type test Report from Central govt/ NABL/ ILAC accredited laboratory to prove conformity to the specification	Yes	*
	Name of lab where test conducted	-	*
	Test certificate number	-	*
	Test report date	-	*

Test report to be submitted to the Buyer on Demand	Yes	*
Marking of manufacturer name /Trade mark on accessories	Yes	*
OEM Product Series	-	*

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

#### Additional Specification Documents

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Anbazhagan P	635701,Kavalur Alangayam contact Mr. Rajinikanth :9884534310	50	15

#### Non Modular Electrical Switches And Accessories Flush Type ( 30 meter )

#### Technical Specifications

[\\* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	<b>Electrical Accessory for domestic &amp;&amp; similar purpose</b>	ISI Marked,16A, 1 Way Piono type Switch to IS:3854/1997 with latest amendments	ISI Marked,16A, 1 Way Piono type Switch to IS:3854/1997 with latest amendments
	<b>Product ISI Marked</b>	Yes	Yes
	Valid BIS License Number	-	*
CONSTRUCTIONAL	Shutter with socket	NA	*
	Current carrying part must be of Brass, Copper, or any other superior material	Yes	*
	Type of Accessories	Flush Type	*
	Body material	Polycarbonate Electrical Grade	*
	Color as seen from front (Matching with other accessories)	Off white	*
	Accessories shall be provided with fixing screw with each set of packing	Yes	*
	Mechanical Strength of Coaxial Antina Socket, Telephone Jack and Indicator as per IS:3854	NA	*
FUNCTIONAL	Rated Voltage (Volt)	250 vOLT	*
	Resistance to Abnormal Heat and Fire of Coaxial Antina Socket, Telephone	NA	*

	Jack and Indicator as per IS:3854		
CERTIFICATIONS	Availability of complete and satisfactory type test Report from Central govt/ NABL/ ILAC accredited laboratory to prove conformity to the specification	Yes	*
	Name of lab where test conducted	-	*
	Test certificate number	-	*
	Test report date	-	*
	Test report to be submitted to the Buyer on Demand	Yes	*
	Marking of manufacturer name /Trade mark on accessories	Yes	*
	OEM Product Series	-	*

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

#### Additional Specification Documents

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Anbazhagan P	635701,Kavalur Alangayam contact Mr. Rajinikanth :9884534310	30	15

#### Bid Specific Additional Terms and Conditions

- 1.Scope of supply (Bid price to include all cost components) : Only supply of Goods
- 2.The buyer organization is an institution eligible for concessional rates of GST as notified by the Government of India. The goods for which bids have been invited fall under classification of GST concession and the conditions for eligibility of concession are met by the institution. A certificate to this effect will be issued by Buyer to the Seller after award of the Contract. Sellers are requested to submit their bids after accounting for the Concessional rate of GST.

Applicable Concessional rate of GST : 5%

Notification No.and date : 47/2017 dated 14/11/2017

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---