

No.PR/RVS/VBO/DG-SET/CAP/772

Dated: 22nd February 2011

CORIGENDUM – I

Sub: Public Tender Notice No.PR/RVS/VBO/DG-SET/CAP/772 dated 25th January 2011 on IIA website for Supply of 256KW / 350 KVA DG-SET as per the specifications in the Annexure I – reg.

I.FOR: Annexure I “to the existing entry”

READ

ANNEXURE – I

Supply and installation of 256 KW / 320 KVA DG-SET (Diesel Generating Set) radiator cooled type with “CUMMINS” Engine Model: NTA 8550-38-G2-I, developing 380 BhP at 1500rpm coupled with **Stamford alternator rated at 280 KW/ 350 KVA mounted on a channel iron base frame with set of AVM pads, heavy duty Air cleaner, Make: DG Set Kirloskar “Cummins”**

- a).Skid mounted fuel tank
- b).Residential Silencers with bellows
- c).Starting batteries with leads
- d).Powercom
- e).First fill of libe oil and radiator coolant
- f).Automatic mains failure (AMF) panel (double breaker) – 1 No.

II. Last date for submission of bids is extended upto 7th March 2011 at 15.00 hours.

III. All other terms and conditions are remain unaltered.

**Administrative Officer
IIA, Bangalore**

